



Nick Subotsch  
Technical Director  
Peerless Industrial Systems  
2 / 79 Robinson Avenue  
BELMONT WA 6104

Dear Mr Subotsch

**EPIGEN 1311 - APPROVAL**

Thank you for your application seeking renewal of approval to use Epigen 1311 high build epoxy coating for use related to drinking water applications in Western Australia.

The product **EPIGEN 1311** is approved subject to the following conditions:

- Approval has been based upon demonstrated compliance with AS/NZS 4020:2018;
- Usage shall be in accordance with the manufacturer's recommendations, and not to exceed an exposure of 6,600 mm<sup>2</sup> per litre; and
- Re-approval for use in Western Australia must be sought if there is any change in the formulation of the product.

The product will be listed under Schedule 5 of the Department's "[Materials and Substances in Contact with Drinking Water](#)" factsheet. The supplied Safety Data Sheets will be held by the Department of Health WA in confidence. As Epigen 1311 has been previously listed under Schedule 5, this approval can be regarded as a renewal.

Please note that this does not constitute an endorsement of any product by the Department of Health WA and should not be advertised as such. If you require any additional information, please contact Mr Brian Labza of this office on (08) 9222 0241.

Yours sincerely

Richard Theobald  
**Managing Scientist**  
**Water**

9 May 2023