



Nick Subotsch  
Technical Director  
Peerless Industrial Systems  
2 / 79 Robinson Avenue  
BELMONT WA 6104

Dear Mr Subotsch

**EPIGEN Products 1311 Ultra / 1344 / 0402- APPROVAL**

Thank you for your application seeking approval to use Epigen 1311 Ultra and Epigen 1344 high build epoxy coatings, and Epigen 0402 epoxy resin binder system, for use related to drinking water applications in Western Australia.

The products **EPIGEN 1311 Ultra**, **EPIGEN 1344** and **EPIGEN 0402** are approved subject to the following conditions:

- Approval has been based upon demonstrated compliance with AS/NZS 4020:2018;
- Usage shall be in accordance with the manufacturer's recommendations, with due regard to occupational safety for users or operators and any relevant Dangerous Goods requirements; and
- Usage shall not exceed an exposure of 8,400 mm<sup>2</sup> per litre for Epigen 1311 Ultra, 15,000 mm<sup>2</sup> per litre for Epigen 1344 and 15,000 mm<sup>2</sup> per litre for Epigen 0402.
- Re-approval for use in Western Australia must be sought if there is any change in the formulation of the product.

The products will be listed under Schedule 5 of the Department's "[Materials and Substances in Contact with Drinking Water](#)" factsheet. The supplied Safety Data Sheets will be held by the Department of Health WA in confidence.

Please note that this does not constitute an endorsement of any product by the Department of Health WA and should not be advertised as such. If you require any additional information, please contact Mr Brian Labza of this office on (08) 9222 0241.

Yours sincerely

Richard Theobald  
**Managing Scientist**  
**Water**

17 October 2025